

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Drinking Water**
 Location : Near Set 3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	181	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	1.03	1.0 Max.	5	IS 3025 (P-10)
6	pH value	-	7.30	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
1	Ammonia	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 24 th ED.
2	Anionic Detergents (as MBAS)	mg/L	BLQ, (LOQ-0.01)	0.2 Max.	1	APHA 24 th ED.
3	Calcium (as Ca)	mg/L	42.4	75 Max.	200	IS 3025 (P-40)
4	Chloramines (as Cl ₂)	mg/L	BLQ, (LOQ-0.05)	4 Max.	No Relaxation	APHA 24 th ED.
5	Chloride (as Cl)	mg/L	5.5	250 Max.	1000	IS 3025 (P-32)
6	Cyanide (as CN)	mg/L	BLQ, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 24 th ED.
7	Fluoride (as F)	mg/L	0.15	1.0 Max.	1.5	APHA 24 th ED.
8	Magnesium (as Mg)	mg/L	16.52	30 Max.	100	IS-3025 (P-46)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Drinking Water**
 Location : Near Set 3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
9	Mineral oil	mg/L	BLQ, (LOQ-0.1)	1.0 Max.	No Relaxation	IS 3025 (P-39)
10	Nitrate (as NO ₃)	mg/L	3.57	45 Max.	No Relaxation	APHA 24 th ED.
11	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	BLQ, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/05-14
12	Phenolic substances (as C ₆ H ₅ OH)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	0.002	APHA 24 th ED.
13	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/05-07
14	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	1	APHA 24 th ED.
15	Sulphate (as SO ₄)	mg/L	6.91	200 Max.	400	APHA 24 th ED.
16	Sulphide (as H ₂ S)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	No Relaxation	APHA 24 th ED.
17	Total Alkalinity (as CaCO ₃)	mg/L	155	200 Max.	600	IS:3025 (P-23)
18	Total Hardness (as CaCO ₃)	mg/L	174	200 Max.	600	IS 3025 (P-21)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Drinking Water**
 Location : Near Set 3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
1	Aluminium (as Al)	mg/L	BLQ, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/12-01
2	Arsenic (as As)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
3	Barium (as Ba)	mg/L	BLQ, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/12-01
4	Boron (as B)	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/12-01
5	Cadmium (as Cd)	mg/L	BLQ, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/12-01
6	Chromium (as Cr)	mg/L	BLQ, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/12-01
7	Copper (as Cu)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/12-01
8	Iron (as Fe)	mg/L	0.079	1.0 Max.	No Relaxation	FL/SOP/12-01
9	Lead (as Pb)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
10	Manganese (as Mn)	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/12-01
11	Mercury (as Hg)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/12-01
12	Molybdenum (as Mo)	mg/L	BLQ, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/12-01
13	Nickel (as Ni)	mg/L	BLQ, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/12-01
14	Selenium (as Se)	mg/L	BLQ, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/12-01
15	Silver (as Ag)	mg/L	BLQ, (LOQ-0.02)	0.1 Max.	No Relaxation	FL/SOP/12-01
16	Uranium (as U)	mg/L	BLQ, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/12-01

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample
 Location
 Source of Water

: Drinking Water
 : Near Set 3
 : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging
 Test started on
 Test Completed
 Method of Sampling
 Date of Sampling
 Sample Collected by

: 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 : 21-05-2026
 : 26-05-2026
 : FL/SOP/B/D-1
 : 21-05-2026
 : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
17	Zinc (as Zn)	mg/L	BLQ, (LOQ-0.01)	5.0 Max.	15	FL/SOP/12-01
Trihalomethanes (THM)						
1	Bromodichloromethane	mg/L	BLQ, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/02-26
2	Bromoform	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
3	Chloroform	mg/L	BLQ, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/02-26
4	Dibromochloromethane	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
Pesticide Residues						
1	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/03-02
2	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/05-02
3	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/05-02
4	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
5	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/03-02
6	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02
7	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/05-02
8	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/05-02
9	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Drinking Water**
 Location : Near Set 3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
10	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
11	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
12	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
13	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
14	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/05-02
15	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
16	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/05-02
17	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/05-02
18	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/05-02
19	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/03-02
20	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
21	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
22	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
23	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
24	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
25	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample
 Location
 Source of Water

: Drinking Water
 : Near Set 3
 : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging
 Test started on
 Test Completed
 Method of Sampling
 Date of Sampling
 Sample Collected by

: 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 : 21-05-2026
 : 26-05-2026
 : FL/SOP/B/D-1
 : 21-05-2026
 : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
26	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of this test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-097
 ULR Code : TC5503 26 2 00023079 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Drinking Water**
 Location : Near Set 3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

LOQ= Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: FL/SOP/05-14, FL/SOP/05-07 Based on AOAC 990.06; FL/SOP/02-26 Based on APHA 24th Ed.

Note: FL/SOP/03-02, FL/SOP/05-02 Based on AOAC 990.06

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012) in case of permissible limit, with respect to above tests only.

Meenakshi Bakshi

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	395	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	0.38	1.0 Max.	5	IS 3025 (P-10)
6	pH value	-	7.54	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
1	Ammonia	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 24 th ED.
2	Anionic Detergents (as MBAS)	mg/L	BLQ, (LOQ-0.01)	0.2 Max.	1	APHA 24 th ED.
3	Calcium (as Ca)	mg/L	47.2	75 Max.	200	IS 3025 (P-40)
4	Chloramines (as Cl ₂)	mg/L	BLQ, (LOQ-0.05)	4 Max.	No Relaxation	APHA 24 th ED.
5	Chloride (as Cl)	mg/L	16.5	250 Max.	1000	IS 3025 (P-32)
6	Cyanide (as CN)	mg/L	BLQ, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 24 th ED.
7	Fluoride (as F)	mg/L	0.28	1.0 Max.	1.5	APHA 24 th ED.
8	Magnesium (as Mg)	mg/L	23.33	30 Max.	100	IS-3025 (P-46)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
9	Mineral oil	mg/L	BLQ, (LOQ-0.1)	1.0 Max.	No Relaxation	IS 3025 (P-39)
10	Nitrate (as NO ₃)	mg/L	0.87	45 Max.	No Relaxation	APHA 24 th ED.
11	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	BLQ, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/05-14
12	Phenolic substances (as C ₆ H ₅ OH)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	0.002	APHA 24 th ED.
13	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/05-07
14	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	1	APHA 24 th ED.
15	Sulphate (as SO ₄)	mg/L	20.68	200 Max.	400	APHA 24 th ED.
16	Sulphide (as H ₂ S)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	No Relaxation	APHA 24 th ED.
17	Total Alkalinity (as CaCO ₃)	mg/L	235	200 Max.	600	IS:3025 (P-23)
18	Total Hardness (as CaCO ₃)	mg/L	214	200 Max.	600	IS 3025 (P-21)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
1	Aluminium (as Al)	mg/L	BLQ, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/12-01
2	Arsenic (as As)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
3	Barium (as Ba)	mg/L	BLQ, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/12-01
4	Boron (as B)	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/12-01
5	Cadmium (as Cd)	mg/L	BLQ, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/12-01
6	Chromium (as Cr)	mg/L	BLQ, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/12-01
7	Copper (as Cu)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/12-01
8	Iron (as Fe)	mg/L	0.077	1.0 Max.	No Relaxation	FL/SOP/12-01
9	Lead (as Pb)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
10	Manganese (as Mn)	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/12-01
11	Mercury (as Hg)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/12-01
12	Molybdenum (as Mo)	mg/L	BLQ, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/12-01
13	Nickel (as Ni)	mg/L	BLQ, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/12-01
14	Selenium (as Se)	mg/L	BLQ, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/12-01
15	Silver (as Ag)	mg/L	BLQ, (LOQ-0.02)	0.1 Max.	No Relaxation	FL/SOP/12-01
16	Uranium (as U)	mg/L	BLQ, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/12-01

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
17	Zinc (as Zn)	mg/L	BLQ, (LOQ-0.01)	5.0 Max.	15	FL/SOP/12-01
Trihalomethanes (THM)						
1	Bromodichloromethane	mg/L	BLQ, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/02-26
2	Bromoform	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
3	Chloroform	mg/L	BLQ, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/02-26
4	Dibromochloromethane	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
Pesticide Residues						
1	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/03-02
2	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/05-02
3	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/05-02
4	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
5	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/03-02
6	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02
7	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/05-02
8	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/05-02
9	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
10	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
11	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
12	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
13	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
14	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/05-02
15	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
16	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/05-02
17	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/05-02
18	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/05-02
19	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/03-02
20	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
21	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
22	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
23	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
24	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
25	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
26	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of this test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-098
 ULR Code : TC5503 26 2 00023080 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -6
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

LOQ= Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: FL/SOP/05-14, FL/SOP/05-07 Based on AOAC 990.06; FL/SOP/02-26 Based on APHA 24th Ed.

Note: FL/SOP/03-02, FL/SOP/05-02 Based on AOAC 990.06

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012) in case of permissible limit, with respect to above tests only.

Meenakshi Bakshi

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	380	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	0.33	1.0 Max.	5	IS 3025 (P-10)
6	pH value	-	7.77	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
1	Ammonia	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 24 th ED.
2	Anionic Detergents (as MBAS)	mg/L	BLQ, (LOQ-0.01)	0.2 Max.	1	APHA 24 th ED.
3	Calcium (as Ca)	mg/L	45.6	75 Max.	200	IS 3025 (P-40)
4	Chloramines (as Cl ₂)	mg/L	BLQ, (LOQ-0.05)	4 Max.	No Relaxation	APHA 24 th ED.
5	Chloride (as Cl)	mg/L	18.99	250 Max.	1000	IS 3025 (P-32)
6	Cyanide (as CN)	mg/L	BLQ, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 24 th ED.
7	Fluoride (as F)	mg/L	0.27	1.0 Max.	1.5	APHA 24 th ED.
8	Magnesium (as Mg)	mg/L	19.93	30 Max.	100	IS-3025 (P-46)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
9	Mineral oil	mg/L	BLQ, (LOQ-0.1)	1.0 Max.	No Relaxation	IS 3025 (P-39)
10	Nitrate (as NO ₃)	mg/L	4.79	45 Max.	No Relaxation	APHA 24 th ED.
11	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	BLQ, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/05-14
12	Phenolic substances (as C ₆ H ₅ OH)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	0.002	APHA 24 th ED.
13	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/05-07
14	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	1	APHA 24 th ED.
15	Sulphate (as SO ₄)	mg/L	22.92	200 Max.	400	APHA 24 th ED.
16	Sulphide (as H ₂ S)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	No Relaxation	APHA 24 th ED.
17	Total Alkalinity (as CaCO ₃)	mg/L	265	200 Max.	600	IS:3025 (P-23)
18	Total Hardness (as CaCO ₃)	mg/L	196	200 Max.	600	IS 3025 (P-21)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
1	Aluminium (as Al)	mg/L	BLQ, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/12-01
2	Arsenic (as As)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
3	Barium (as Ba)	mg/L	BLQ, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/12-01
4	Boron (as B)	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/12-01
5	Cadmium (as Cd)	mg/L	BLQ, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/12-01
6	Chromium (as Cr)	mg/L	BLQ, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/12-01
7	Copper (as Cu)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/12-01
8	Iron (as Fe)	mg/L	0.084	1.0 Max.	No Relaxation	FL/SOP/12-01
9	Lead (as Pb)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
10	Manganese (as Mn)	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/12-01
11	Mercury (as Hg)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/12-01
12	Molybdenum (as Mo)	mg/L	BLQ, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/12-01
13	Nickel (as Ni)	mg/L	BLQ, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/12-01
14	Selenium (as Se)	mg/L	BLQ, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/12-01
15	Silver (as Ag)	mg/L	BLQ, (LOQ-0.02)	0.1 Max.	No Relaxation	FL/SOP/12-01
16	Uranium (as U)	mg/L	BLQ, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/12-01

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
17	Zinc (as Zn)	mg/L	BLQ, (LOQ-0.01)	5.0 Max.	15	FL/SOP/12-01
Trihalomethanes (THM)						
1	Bromodichloromethane	mg/L	BLQ, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/02-26
2	Bromoform	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
3	Chloroform	mg/L	BLQ, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/02-26
4	Dibromochloromethane	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
Pesticide Residues						
1	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/03-02
2	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/05-02
3	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/05-02
4	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
5	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/03-02
6	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02
7	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/05-02
8	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/05-02
9	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
10	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
11	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
12	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
13	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
14	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/05-02
15	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
16	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/05-02
17	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/05-02
18	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/05-02
19	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/03-02
20	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
21	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
22	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
23	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
24	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
25	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
26	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of this test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-099
 ULR Code : TC5503 26 2 00023081 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -3
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

LOQ= Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: FL/SOP/05-14, FL/SOP/05-07 Based on AOAC 990.06; FL/SOP/02-26 Based on APHA 24th Ed.

Note: FL/SOP/03-02, FL/SOP/05-02 Based on AOAC 990.06

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012) in case of permissible limit, with respect to above tests only.

Meenakshi Bakshi

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	318	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	0.42	1.0 Max.	5	IS 3025 (P-10)
6	pH value	-	7.80	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
1	Ammonia	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 24 th ED.
2	Anionic Detergents (as MBAS)	mg/L	BLQ, (LOQ-0.01)	0.2 Max.	1	APHA 24 th ED.
3	Calcium (as Ca)	mg/L	56.8	75 Max.	200	IS 3025 (P-40)
4	Chloramines (as Cl ₂)	mg/L	BLQ, (LOQ-0.05)	4 Max.	No Relaxation	APHA 24 th ED.
5	Chloride (as Cl)	mg/L	11.5	250 Max.	1000	IS 3025 (P-32)
6	Cyanide (as CN)	mg/L	BLQ, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 24 th ED.
7	Fluoride (as F)	mg/L	0.22	1.0 Max.	1.5	APHA 24 th ED.
8	Magnesium (as Mg)	mg/L	25.27	30 Max.	100	IS-3025 (P-46)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
9	Mineral oil	mg/L	BLQ, (LOQ-0.1)	1.0 Max.	No Relaxation	IS 3025 (P-39)
10	Nitrate (as NO ₃)	mg/L	7.87	45 Max.	No Relaxation	APHA 24 th ED.
11	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	BLQ, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/05-14
12	Phenolic substances (as C ₆ H ₅ OH)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	0.002	APHA 24 th ED.
13	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/05-07
14	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	1	APHA 24 th ED.
15	Sulphate (as SO ₄)	mg/L	7.01	200 Max.	400	APHA 24 th ED.
16	Sulphide (as H ₂ S)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	No Relaxation	APHA 24 th ED.
17	Total Alkalinity (as CaCO ₃)	mg/L	235	200 Max.	600	IS:3025 (P-23)
18	Total Hardness (as CaCO ₃)	mg/L	246	200 Max.	600	IS 3025 (P-21)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
1	Aluminium (as Al)	mg/L	BLQ, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/12-01
2	Arsenic (as As)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
3	Barium (as Ba)	mg/L	BLQ, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/12-01
4	Boron (as B)	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/12-01
5	Cadmium (as Cd)	mg/L	BLQ, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/12-01
6	Chromium (as Cr)	mg/L	BLQ, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/12-01
7	Copper (as Cu)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/12-01
8	Iron (as Fe)	mg/L	0.088	1.0 Max.	No Relaxation	FL/SOP/12-01
9	Lead (as Pb)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
10	Manganese (as Mn)	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/12-01
11	Mercury (as Hg)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/12-01
12	Molybdenum (as Mo)	mg/L	BLQ, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/12-01
13	Nickel (as Ni)	mg/L	BLQ, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/12-01
14	Selenium (as Se)	mg/L	BLQ, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/12-01
15	Silver (as Ag)	mg/L	BLQ, (LOQ-0.02)	0.1 Max.	No Relaxation	FL/SOP/12-01
16	Uranium (as U)	mg/L	BLQ, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/12-01

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
17	Zinc (as Zn)	mg/L	BLQ, (LOQ-0.01)	5.0 Max.	15	FL/SOP/12-01
Trihalomethanes (THM)						
1	Bromodichloromethane	mg/L	BLQ, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/02-26
2	Bromoform	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
3	Chloroform	mg/L	BLQ, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/02-26
4	Dibromochloromethane	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
Pesticide Residues						
1	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/03-02
2	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/05-02
3	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/05-02
4	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
5	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/03-02
6	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02
7	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/05-02
8	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/05-02
9	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
10	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
11	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
12	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
13	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
14	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/05-02
15	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
16	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/05-02
17	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/05-02
18	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/05-02
19	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/03-02
20	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
21	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
22	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
23	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
24	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
25	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
26	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of this test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-100
 ULR Code : TC5503 26 2 00023082 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -2
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

LOQ= Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: FL/SOP/05-14, FL/SOP/05-07 Based on AOAC 990.06; FL/SOP/02-26 Based on APHA 24th Ed.

Note: FL/SOP/03-02, FL/SOP/05-02 Based on AOAC 990.06

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012) in case of permissible limit, with respect to above tests only.

Meenakshi Bakshi

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

Physical Description : Water is clear without any sediments, suspended particles & extraneous matter.

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Organoleptic & Physical Parameters						
1	Colour	Hazen	2	5 Max.	15	IS 3025 (P-4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-5)
3	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (P-7&8)
4	Total Dissolved Solids	mg/L	328	500 Max.	2000	IS 3025 (P-16)
5	Turbidity	NTU	0.78	1.0 Max.	5	IS 3025 (P-10)
6	pH value	-	7.54	6.5-8.5	No Relaxation	IS 3025 (P-11)
Chemical Analysis						
1	Ammonia	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	No Relaxation	APHA 24 th ED.
2	Anionic Detergents (as MBAS)	mg/L	BLQ, (LOQ-0.01)	0.2 Max.	1	APHA 24 th ED.
3	Calcium (as Ca)	mg/L	55.2	75 Max.	200	IS 3025 (P-40)
4	Chloramines (as Cl ₂)	mg/L	BLQ, (LOQ-0.05)	4 Max.	No Relaxation	APHA 24 th ED.
5	Chloride (as Cl)	mg/L	16.5	250 Max.	1000	IS 3025 (P-32)
6	Cyanide (as CN)	mg/L	BLQ, (LOQ-0.03)	0.05 Max.	No Relaxation	APHA 24 th ED.
7	Fluoride (as F)	mg/L	0.25	1.0 Max.	1.5	APHA 24 th ED.
8	Magnesium (as Mg)	mg/L	25.27	30 Max.	100	IS-3025 (P-46)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Chemical Analysis						
9	Mineral oil	mg/L	BLQ, (LOQ-0.1)	1.0 Max.	No Relaxation	IS 3025 (P-39)
10	Nitrate (as NO ₃)	mg/L	0.58	45 Max.	No Relaxation	APHA 24 th ED.
11	Polynuclear aromatic hydrocarbons (as PAHs)	mg/L	BLQ, (LOQ-0.00001)	0.0001 Max.	No Relaxation	FL/SOP/05-14
12	Phenolic substances (as C ₆ H ₅ OH)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	0.002	APHA 24 th ED.
13	Polychlorinated biphenyls	mg/L	BLQ, (LOQ-0.00001)	0.0005 Max.	No Relaxation	FL/SOP/05-07
14	Residual Free Chlorine	mg/L	BLQ, (LOQ-0.1)	0.2 Min.	1	APHA 24 th ED.
15	Sulphate (as SO ₄)	mg/L	10.19	200 Max.	400	APHA 24 th ED.
16	Sulphide (as H ₂ S)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	No Relaxation	APHA 24 th ED.
17	Total Alkalinity (as CaCO ₃)	mg/L	220	200 Max.	600	IS:3025 (P-23)
18	Total Hardness (as CaCO ₃)	mg/L	242	200 Max.	600	IS 3025 (P-21)

Authorised Signatory
 Ms. Nayla Tazeen, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
1	Aluminium (as Al)	mg/L	BLQ, (LOQ-0.01)	0.03 Max.	0.2	FL/SOP/12-01
2	Arsenic (as As)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
3	Barium (as Ba)	mg/L	BLQ, (LOQ-0.01)	0.7 Max.	No Relaxation	FL/SOP/12-01
4	Boron (as B)	mg/L	BLQ, (LOQ-0.01)	0.5 Max.	2.4	FL/SOP/12-01
5	Cadmium (as Cd)	mg/L	BLQ, (LOQ-0.001)	0.003 Max.	No Relaxation	FL/SOP/12-01
6	Chromium (as Cr)	mg/L	BLQ, (LOQ-0.005)	0.05 Max.	No Relaxation	FL/SOP/12-01
7	Copper (as Cu)	mg/L	BLQ, (LOQ-0.01)	0.05 Max.	1.5	FL/SOP/12-01
8	Iron (as Fe)	mg/L	0.073	1.0 Max.	No Relaxation	FL/SOP/12-01
9	Lead (as Pb)	mg/L	BLQ, (LOQ-0.002)	0.01 Max.	No Relaxation	FL/SOP/12-01
10	Manganese (as Mn)	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	0.3	FL/SOP/12-01
11	Mercury (as Hg)	mg/L	BLQ, (LOQ-0.0005)	0.001 Max.	No Relaxation	FL/SOP/12-01
12	Molybdenum (as Mo)	mg/L	BLQ, (LOQ-0.002)	0.07 Max.	No Relaxation	FL/SOP/12-01
13	Nickel (as Ni)	mg/L	BLQ, (LOQ-0.002)	0.02 Max.	No Relaxation	FL/SOP/12-01
14	Selenium (as Se)	mg/L	BLQ, (LOQ-0.005)	0.01 Max.	No Relaxation	FL/SOP/12-01
15	Silver (as Ag)	mg/L	BLQ, (LOQ-0.02)	0.1 Max.	No Relaxation	FL/SOP/12-01
16	Uranium (as U)	mg/L	BLQ, (LOQ-0.005)	0.03 Max.	No Relaxation	FL/SOP/12-01

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Metal Analysis						
17	Zinc (as Zn)	mg/L	BLQ, (LOQ-0.01)	5.0 Max.	15	FL/SOP/12-01
Trihalomethanes (THM)						
1	Bromodichloromethane	mg/L	BLQ, (LOQ-0.005)	0.06 Max.	No Relaxation	FL/SOP/02-26
2	Bromoform	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
3	Chloroform	mg/L	BLQ, (LOQ-0.005)	0.2 Max.	No Relaxation	FL/SOP/02-26
4	Dibromochloromethane	mg/L	BLQ, (LOQ-0.005)	0.1 Max.	No Relaxation	FL/SOP/02-26
Pesticide Residues						
1	2,4- Dichlorophenoxyacetic acid	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/03-02
2	Alachlor	µg/L	BLQ, (LOQ-0.01)	20 Max.	No Relaxation	FL/SOP/05-02
3	Alpha HCH	µg/L	BLQ, (LOQ-0.01)	0.01 Max.	No Relaxation	FL/SOP/05-02
4	Aldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
5	Atrazine	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/03-02
6	Beta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02
7	Butachlor	µg/L	BLQ, (LOQ-0.01)	125 Max.	No Relaxation	FL/SOP/05-02
8	Chlorpyrifos	µg/L	BLQ, (LOQ-0.01)	30 Max.	No Relaxation	FL/SOP/05-02
9	Delta HCH	µg/L	BLQ, (LOQ-0.01)	0.04 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
10	Dieldrin	µg/L	BLQ, (LOQ-0.01)	0.03 Max.	No Relaxation	FL/SOP/05-02
11	Endosulfan-alpha	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
12	Endosulfan-sulphate	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
13	Endosulfan-beta	µg/L	BLQ, (LOQ-0.01)	0.4 Max.	No Relaxation	FL/SOP/05-02
14	Ethion	µg/L	BLQ, (LOQ-0.01)	3 Max.	No Relaxation	FL/SOP/05-02
15	Gamma - HCH (Lindane)	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
16	Isoproturon	µg/L	BLQ, (LOQ-0.01)	9 Max.	No Relaxation	FL/SOP/05-02
17	Malathion	µg/L	BLQ, (LOQ-0.01)	190 Max.	No Relaxation	FL/SOP/05-02
18	Methyl parathion	µg/L	BLQ, (LOQ-0.01)	0.3 Max.	No Relaxation	FL/SOP/05-02
19	Monocrotophos	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/03-02
20	o,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
21	p,p-DDE	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
22	Phorate	µg/L	BLQ, (LOQ-0.01)	2 Max.	No Relaxation	FL/SOP/05-02
23	o,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
24	o,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02
25	p,p- DDD	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Pesticide Residues						
26	p,p-DDT	µg/L	BLQ, (LOQ-0.01)	1 Max.	No Relaxation	FL/SOP/05-02

Authorised Signatory
 Mr. Mithilesh Kumar, Scientist-B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of this test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

TEST REPORT

Issued to :
RE Sustainability Limited (Unit: Punjab Waste Management Project)
 Village- Nimbua, Tehsil- Derabassi, District- Mohali
 Punjab
 -140507
 Punjab, India

J.O. No. : W20260521-053-101
 ULR Code : TC5503 26 2 00023083 F
 Issue Date : 26-05-2026
 Sample Receipt Date : 21-05-2026
 Account Manager : BD Team 1
 Credit Manager : Gulab/Septesh



Customer Provided Information:#

Nature/Name of the Sample : **Borewell Water**
 Location : Borewell No -4
 Source of Water : Borewell

Laboratory Provided Information:

Sample Quantity & Packaging : 1Litre x 10 Pet Bottle, 500ml Sterilized Bottle
 Test started on : 21-05-2026
 Test Completed : 26-05-2026
 Method of Sampling : FL/SOP/B/D-1
 Date of Sampling : 21-05-2026
 Sample Collected by : Mr. Uttkasrh (FARE LABS Representative) at the premises of RE Sustainability Limited (Unit: Punjab Waste Management Project)



Analysis Report

S. No.	Parameters	Unit	Test Results	Specifications as per IS-10500:2012		Method
				Acceptable Limit	Permissible Limit	
Microbiological Analysis						
1	E. Coli	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185
2	Total Coliform	per 100ml	Absent	Shall not be detectable in any 100ml sample	No Relaxation	IS 15185

LOQ= Limit of Quantification; **BLQ=** Below Limit of Quantification

Note: FL/SOP/12-01, Based on APHA 24th Ed.

Note: FL/SOP/05-14, FL/SOP/05-07 Based on AOAC 990.06; FL/SOP/02-26 Based on APHA 24th Ed.

Note: FL/SOP/03-02, FL/SOP/05-02 Based on AOAC 990.06

Note: RFC-0.2 Min is applicable only when water is chlorinated. Tested at consumer end. When Protection against viral infection is required, it should be minimum 0.5 mg/l.

Opinion: The tested sample of water **conforms** to the specifications of drinking water (IS-10500:2012) in case of permissible limit, with respect to above tests only.

Meenakshi Bakshi

Authorised Signatory

Ms. Meenakshi Bakshi, Scientist B

NOTE: The laboratory accepts the responsibility for content of report. The results contained in this test report pertains only to the sample tested not for the whole lot. Test report shall not be reproduced except in full, without written approval of the laboratory. This report is intended only for your guidance, and not for legal purposes, commercial decision, and for advertisement. Samples will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified. Any complaints about this report should be communicated in writing within 7 days of issue of this report. Total liability at FARELABS Pvt. Ltd. is limited to invoiced amount only. The recipient of this report is requested to kindly confirm with FARE Labs, the authenticity and genuineness of this report at report.confirmation@farelabs.com. FARE Labs is not responsible for any unconfirmed Test Report. If you have any complaint/feedback regarding the sample collection/testing/test report, please send an email at feedback@farelabs.com and call at +91 9312664533.
 #: The details are received from Customer on its own responsibility. FARE Labs Pvt. Ltd. does not Confirm about it and hence does not take any responsibility whatsoever.

*****End of Report*****