



Test Report

Report No.: GECPL/N -202605/04		Date: 26/05/2026	
URL No. TC1375726200004010F			
Name & Address of Customer	:	Re Sustainability Limited Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507., India	
Contact Person	:	-	
Sample Collection Date	:	21/05/2026	Sampling Type : NA
Sample Receipt Date	:	21/05/2026	Sample ID : N -202605/04
Sampling Location	:	DG Noise-01 (125 KVA)	Sample Description : DG Noise monitoring Make & model: Cummins & 6BTA5-9G2-I Serial No.: 62614812
Sample Collected / Submitted by	:	GECPL Team	Protocol used for monitoring : IS 4758:1968
Analysis Started On	:	21/05/2026	Analysis Completed On : 26/05/2026
Instrument calibration status	:	Calibrated	Format No. : 7.8 F-07
Meteorological condition during monitoring	:	Clear Sky	Actual duration of Monitoring, (Minutes.) : 30 Minutes
Meteorological condition during monitoring		25°C ±3 °C	

Test Results

S. No.	Parameters	Unit	Results	Limit as CPCB*	Test Method
1	1.0 Meter From Acoustic Surface	dB(A)	73.4	75Max.	IS 4758:1968
2	Near Acoustic Enclosure	dB(A)	98.6	-	IS 4758:1968
3	Insertion Loss	dB(A)	25.2	25Min.	IS 4758:1968

Remarks: Sampling done by GECPL representative

*CPCB: Central Pollution Control Board

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified By & Authorized Signatory
Mr. Neeraj Kumar yadav
(Quality Manager)



- This Report is issued under the following terms & Condition:
- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results relate only to the above tested sample and applicable Parameters.
 - The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
 - Samples shall be stored for the period of 15 days after the date of issue of Report.



Test Report

Report No.: GECPL/N -202605/05		Date: 26/05/2026	
URL No. TC1375726200004011F			
Name & Address of Customer	:	Re Sustainability Limited Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507., India	
Contact Person	:	-	
Sample Collection Date	:	21/05/2026	Sampling Type : NA
Sample Receipt Date	:	21/05/2026	Sample ID : N -202605/05
Sampling Location	:	DG Noise-02 (380 KVA)	Sample Description : DG Noise monitoring Make & model: Koel & DV8TAG2 Serial No.: DV8.9214/2220002
Sample Collected / Submitted by	:	GECPL Team	Protocol used for monitoring : IS 4758:1968
Analysis Started On	:	21/05/2026	Analysis Completed On : 26/05/2026
Instrument calibration status	:	Calibrated	Format No. : 7.8 F-07
Meteorological condition during monitoring	:	Clear Sky	Actual duration of Monitoring, (Minutes.) : 30 Minutes
Meteorological condition during monitoring		25°C ±3 °C	

Test Results

S. No.	Parameters	Unit	Results	Limit as CPCB*	Test Method
1	1.0 Meter From Acoustic Surface	dB(A)	71.8	75Max.	IS 4758:1968
2	Near Acoustic Enclosure	dB(A)	98.2	-	IS 4758:1968
3	Insertion Loss	dB(A)	26.4	25Min.	IS 4758:1968

Remarks: Sampling done by GECPL representative

*CPCB: Central Pollution Control Board

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified By & Authorized Signatory
Mr. Neeraj Kumar yadav
(Quality Manager)



This Report is issued under the following terms & Condition:

- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results relate only to the above tested sample and applicable Parameters.
- The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
- Samples shall be stored for the period of 15 days after the date of issue of Report.



TEST REPORT

Report No.: GECPL/N-202605/06		Date: 26/05/2026	
ULR No.: TC1375726200004001F			
Name & Address of Customer	Re Sustainability Limited : Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507, India		
Contact Person	: -		
Sample Collection Date	: 19/05/2026 to 20/05/2026	Sampling Type	: NA
Sample Receipt Date	: 21/05/2026	Sample ID	: N-202605/06
Sampling Location	: Near Main Gate	Sample Description	: Ambient Noise Monitoring
Sample Collected/ Submitted by	: GECPL Team	Protocol used for monitoring	: IS 9989-2023
Analysis Started On	: 21/05/2026	Analysis Completed On	: 26/05/2026
Instrument calibration status	: Calibrated	Format No.	: 7.8 F-07
Meteorological condition during monitoring	: Clear Sky	Actual duration of Monitoring, (Hrs.)	: 24 Hrs.
Meteorological condition during monitoring	25°C ±3 °C		

Ambient Noise Analysis Results

S.No.	Parameters	Day Time (dB(A))	Night Time (dB(A))	Test Method
1.	Lmax	63.1	54.6	IS 9989 : 1981 (Reaffirmed Year: 2023)
2.	Lmin	53.8	43.8	
3.	Leq	57.6	49.3	
<ul style="list-style-type: none"> • Day time: 06:00 am to 10:00 pm • Night time: 10:00 pm to 06:00 am 				

Ambient Noise Quality Standards as per Noise Pollution (Regulation and control) Rules, 2000

Area Code	Category of Area/Zone	Limits in dB (A) Leq*	
		Day Time	Night Time
A	Industrial area	75	70
B	Commercial area	65	55
C	Residential area	55	45
D	Silence zone	50	40

Remark: Sampling done by GECPL representative

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified by & Authorized Signatory
Mr. NeeraJ Kumar yadav
(Quality Manager)



This Report is issued under the following terms & Condition:

- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
- The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
- Samples shall be stored for the period of 15 days after the date of issue of Report.



TEST REPORT

Report No.: GECPL/N-202605/07		Date: 26/05/2026	
ULR No.: TC1375726200004002F			
Name & Address of Customer	Re Sustainability Limited : Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507., India		
Contact Person	: -		
Sample Collection Date	: 19/05/2026 to 20/05/2026	Sampling Type	: NA
Sample Receipt Date	: 21/05/2026	Sample ID	: N-202605/07
Sampling Location	: Near DG Room	Sample Description	: Ambient Noise Monitoring
Sample Collected/ Submitted by	: GECPL Team	Protocol used for monitoring	: IS 9989-2023
Analysis Started On	: 21/05/2026	Analysis Completed On	: 26/05/2026
Instrument calibration status	: Calibrated	Format No.	: 7.8 F-07
Meteorological condition during monitoring	: Clear Sky	Actual duration of Monitoring, (Hrs.)	: 24 Hrs.
Meteorological condition during monitoring	25°C ±3 °C		

Ambient Noise Analysis Results

S.No.	Parameters	Day Time (dB(A))	Night Time (dB(A))	Test Method
1.	Lmax	58.4	49.2	IS 9989 : 1981 (Reaffirmed Year: 2023)
2.	Lmin	47.8	38.9	
3.	Leq	54.3	45.2	
<ul style="list-style-type: none"> • Day time: 06:00 am to 10:00 pm • Night time: 10:00 pm to 06:00 am 				

Ambient Noise Quality Standards as per Noise Pollution (Regulation and control) Rules, 2000

Area Code	Category of Area/Zone	Limits in dB (A) Leq*	
		Day Time	Night Time
A	Industrial area	75	70
B	Commercial area	65	55
C	Residential area	55	45
D	Silence zone	50	40

Remark: Sampling done by GECPL representative

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified by & Authorized Signatory
Mr. NeeraJ Kumar yadav
(Quality Manager)

This Report is issued under the following terms & Condition:

- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
- The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
- Samples shall be stored for the period of 15 days after the date of issue of Report.



TEST REPORT

Report No.: GECPL/N-202605/08		Date: 26/05/2026	
ULR No.: TC1375726200004003F			
Name & Address of Customer	Re Sustainability Limited : Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507., India		
Contact Person	: -		
Sample Collection Date	: 19/05/2026 to 20/05/2026	Sampling Type	: NA
Sample Receipt Date	: 21/05/2026	Sample ID	: N-202605/08
Sampling Location	: Near INC Area	Sample Description	: Ambient Noise Monitoring
Sample Collected/ Submitted by	: GECPL Team	Protocol used for monitoring	: IS 9989-2023
Analysis Started On	: 21/05/2026	Analysis Completed On	: 26/05/2026
Instrument calibration status	: Calibrated	Format No.	: 7.8 F-07
Meteorological condition during monitoring	: Clear Sky	Actual duration of Monitoring, (Hrs.)	: 24 Hrs.
Meteorological condition during monitoring	25°C ±3 °C		

Ambient Noise Analysis Results

S.No.	Parameters	Day Time (dB(A))	Night Time (dB(A))	Test Method
1.	Lmax	56.2	57.4	IS 9989 : 1981 (Reaffirmed Year: 2023)
2.	Lmin	63.9	48.5	
3.	Leq	59.6	53.1	
<ul style="list-style-type: none"> • Day time: 06:00 am to 10:00 pm • Night time: 10:00 pm to 06:00 am 				

Ambient Noise Quality Standards as per Noise Pollution (Regulation and control) Rules, 2000

Area Code	Category of Area/Zone	Limits in dB (A) Leq*	
		Day Time	Night Time
A	Industrial area	75	70
B	Commercial area	65	55
C	Residential area	55	45
D	Silence zone	50	40

Remark: Sampling done by GECPL representative

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified by & Authorized Signatory
Mr. Neeraj Kumar yadav
(Quality Manager)



- This Report is issued under the following terms & Condition:
- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
 - The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
 - Samples shall be stored for the period of 15 days after the date of issue of Report.



TEST REPORT

Report No.: GECPL/N-202605/09		Date: 26/05/2026	
ULR No.: TC1375726200004004F			
Name & Address of Customer	Re Sustainability Limited : Village-Nimbua, Tehsil-Derabass, District-Mohali, Punjab, 140507., India		
Contact Person	: -		
Sample Collection Date	: 19/05/2026 to 20/05/2026	Sampling Type	: NA
Sample Receipt Date	: 21/05/2026	Sample ID	: N-202605/09
Sampling Location	: Near MEE Plant Area	Sample Description	: Ambient Noise Monitoring
Sample Collected/ Submitted by	: GECPL Team	Protocol used for monitoring	: IS 9989-2023
Analysis Started On	: 21/05/2026	Analysis Completed On	: 26/05/2026
Instrument calibration status	: Calibrated	Format No.	: 7.8 F-07
Meteorological condition during monitoring	: Clear Sky	Actual duration of Monitoring, (Hrs.)	: 24 Hrs.
Meteorological condition during monitoring	25°C ±3 °C		

Ambient Noise Analysis Results

S.No.	Parameters	Day Time (dB(A))	Night Time (dB(A))	Test Method
1.	Lmax	61.3	55.7	IS 9989 : 1981 (Reaffirmed Year: 2023)
2.	Lmin	53.2	46.5	
3.	Leq	57.3	51.0	
<ul style="list-style-type: none"> • Day time: 06:00 am to 10:00 pm • Night time: 10:00 pm to 06:00 am 				

Ambient Noise Quality Standards as per Noise Pollution (Regulation and control) Rules, 2000

Area Code	Category of Area/Zone	Limits in dB (A) Leq*	
		Day Time	Night Time
A	Industrial area	75	70
B	Commercial area	65	55
C	Residential area	55	45
D	Silence zone	50	40

Remark: Sampling done by GECPL representative

-----End Report-----

Reviewed By
Dr. Rama Srivastava
(Technical Manager)

Verified by & Authorized Signatory
Mr. Neeraj Kumar yadav
(Quality Manager)



This Report is issued under the following terms & Condition:

- Samples are not drawn by Gurukripa Enviro Care Private Limited, unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
- The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Gurukripa Enviro Care Private Limited.
- Samples shall be stored for the period of 15 days after the date of issue of Report.